

DOT CYLINDER REQUALIFICATION / VISUAL INSPECTION REPORT FORM

REFERENCE: CFR TITLE 49 SECTIONS 180.209(g) AND 180.215

COMPANY NAME: _____
 BRANCH CITY/STATE: _____
 BOARD LICENSE #, PERMIT # OR DEALER #: _____
 IDENTIFYING SYMBOL: _____
 DATE: _____
 RESPONSIBLE MANAGER: _____

CYLINDER IDENTIFICATION:	CYLINDER	CYLINDER	CYLINDER
SERIAL NUMBER			
DOT / ICC SPEC. NUMBER			
MANUFACTURER			
PROTECTIVE COATING:	~	~	~
DATE OF MANUFACTURE			
TYPE *			
CONDITION			
CYLINDER INSPECTED FOR:	~	~	~
CORROSION & PITTING			
DENTS			
CUTS, DIGS, & GOUGES			
LEAKS			
FIRE DAMAGE			
BULGES			
NECK DEFECTS			
ATTACHMENTS			
OVERFILL PREVENTION			
PARTS INSTALLED **			
DISPOSITION ***			
DATE INSPECTED			
INSPECTOR'S INITIALS			

*** - **DISPOSITION**

OK = RETURN TO SERVICE
 SC = SCRAP (CONDEMNED)
 R = HOLD FOR AUTHORIZED DEALER

** - **PARTS INSTALLED**

RV = RELIEF VALVE
 O = OPD
 G = GUAGE
 LC = LIQUID CUTOFF
 FV = FILLER VALVE
 RVDC = RELIEF VALVE DATE CODE
 CV = CYLINDER VALVE
 GG = GUAGE GASKET
 LCK = LIQUID CHECK
 FVA = FILLER VALVE ADAPTER

* - **TYPE**

S = STEEL
 A = ALUMINUM
 F = FORKLIFT
 B = BUFFER
 D = DOMESTIC

REQUALIFICATION OF DOMESTIC VAPOR CYLINDERS:

- PERFORM VISUAL AND REQUALIFY AT 12 YEARS, AND EVERY 5 YEARS THEREAFTER
- CYLINDERS UP TO 40# MUST HAVE O.P.D. AT REQUALIFICATION

REQUALIFICATION OF LIFT TRUCK & BUFFER CYLINDERS:

- PERFORM VISUAL, CHANGE RELIEF VALVE AND REQUALIFY AT 12 YEARS
- PERFORM VISUAL AND REQUALIFY EVERY 5 YEARS THEREAFTER
- RELIEF VALVES ARE CHANGED AT 12 YEARS OF AGE AND EVERY 10 YEARS THEREAFTER ACCORDING TO THE DATE ON THE RELIEF VALVE. (REFERENCE: NFPA 58, 2.3.2.5)

REVISED: 10-13-04 IRB &SL